

**Customer: C0388155**

Eurotech International LLC  
PO Box: 1401,  
Raysut Industrial Estate,  
Salalah,  
Oman

---

**Result** Limited testing was undertaken on this product in accordance with the WRAS Material Guidance document, Table 1 (change in method of manufacture). Related test report J-00302847 and related approval number 1509510. This product has satisfied the criteria set out in BS 6920: Part 1: 2014 "Specification" and thus is suitable for use with hot (up to 85°C) and cold water.

---

Customer Name	Eurotech International LLC
Product	Eurotherm PPR Fitting Green (Borouge RA140E)
Test Undertaken	BS 6920: 2014 - Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water
Job Number	J-00302868
PAMS Number	181427

---

**Thank you for having your product tested by NSF Wales Ltd.**

Please contact your Account Manager if you have any questions or concerns pertaining to this report.

**Report Date** 03-OCT-2018

**Report Authorisation** 

Matthew Rees - Materials Laboratory Supervisor



0626

## Result Summary Section

<b>Test</b>	<b>Result</b>
Odour and flavour of water BS 6920: Part 1: 2014, Clause 4 - 23°C	Pass
Odour and flavour of water BS 6920: Part 1: 2014, Clause 4 - 85°C	Pass



**Customer: C0388155**

Eurotech International LLC  
PO Box: 1401,  
Raysut Industrial Estate,  
Salalah,  
Oman

---

**Result** Limited testing was undertaken on this product in accordance with the WRAS Guidance Notes, Appendix A, Table 1 (change from one colour to another colour). Related approval number 1509510. This product has satisfied the criteria set out in BS 6920: Part 1: 2014 "Specification" and thus is suitable for use with hot (up to 85°C) and cold water.

---

Customer Name	Eurotech International LLC
Product	Eurotherm PPR Pipe Green (Borouge RA140E)
Test Undertaken	BS 6920: 2014 - Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water
Job Number	J-00302847
PAMS Number	180575

---

**Thank you for having your product tested by NSF Wales Ltd.**

Please contact your Account Manager if you have any questions or concerns pertaining to this report.

**Report Date** 05-OCT-2018

**Report Authorisation** 

Matthew Rees - Materials Laboratory Supervisor



0626

## Result Summary Section

<b>Test</b>	<b>Result</b>
Odour and flavour of water BS 6920: Part 1: 2014, Clause 4 - 23°C	Pass
Odour and flavour of water BS 6920: Part 1: 2014, Clause 4 - 85°C	Pass
Extraction of Metals BS 6920: Part 1: 2014, Clause 8 - 85°C	Pass