



Unit 30 | Fern Close | Pen-Y-Fan Ind Est | Oakdale | Gwent | NP11 3EH | UK
Tel: +44 (0) 1495 236260 wales@nsf.org | www.nsf.org

TEST REPORT

Customer: C0388156

Eurotech International LLC
PO Box: 1401,
Raysut Industrial Estate,
Salalah
Oman

Result Audit testing was carried out on this material in accordance with the letter from WRAS dated 16/August/2023. Previous approval number 1810542. This product has satisfied the relevant clauses set out in BS 6920: Part 1: 2014 "Specification" for the tests detailed in this report.

Customer Name	Eurotech International LLC
Product	Eurotherm PPR Pipe
Test Undertaken	BS 6920: 2014 - Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water
Job Number	J-00471744
Work Order Number	W0862749

Thank you for having your product tested by NSF Wales Ltd.

Please contact your Account Manager if you have any questions or concerns pertaining to this report.

Report Date 11-APR-2024

Report Authorisation

Eleanor Burger - Senior Project Manager Labs



0626

Result Summary Section

Test	Result
Odour and flavour of water BS 6920: Part 1: 2014, Clause 4 - 23°C	Pass
Odour and flavour of water BS 6920: Part 1: 2014, Clause 4 - 85°C	Pass
Extraction of Metals BS 6920: Part 1: 2014, Clause 8 - 85°C	Pass



Unit 30 | Fern Close | Pen-Y-Fan Ind Est | Oakdale | Gwent | NP11 3EH | UK
Tel: +44 (0) 1495 236260 wales@nsf.org | www.nsf.org

TEST REPORT

Customer: C0388156

Eurotech International LLC
PO Box: 1401,
Raysut Industrial Estate,
Salalah
Oman

Result Audit testing was carried out on this material in accordance with the letter from WRAS dated 16/August/2023. Previous approval number 1810541. This product has satisfied the criteria set out in BS 6920: Part 1: 2014 "Specification" and thus is suitable for use with hot (up to 85°C) and cold water.

Customer Name	Eurotech International LLC
Product	Eurotherm PPR Fitting
Test Undertaken	BS 6920: 2014 - Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water
Job Number	J-00471743
Work Order Number	W0862749

Thank you for having your product tested by NSF Wales Ltd.

Please contact your Account Manager if you have any questions or concerns pertaining to this report.

Report Date 22-MAR-2024

Report Authorisation

Michael Bustin - Materials Testing Manager



0626

Result Summary Section

Test	Result
Odour and flavour of water BS 6920: Part 1: 2014, Clause 4 - 23°C	Pass
Odour and flavour of water BS 6920: Part 1: 2014, Clause 4 - 85°C	Pass