

Approval Number 240455026
Test Report: J-00471744



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

22nd April 2024

Eurotech International LLC (Eurotherm PPR)
PO Box 1401, PC:211,
Raysut Industrial Estate,
Salalah,
Oman

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE- COMPONENTS.

5260

'Eurotherm PPR Pipe'. Green coloured (with yellow coloured stripe), extruded PPR pipe. For use with water up to 85°C.

APPROVAL NUMBER: 240455026

APPROVAL HOLDER: EUROTECH INTERNATIONAL LLC (EUROTHERM PPR)

The Scheme reserves the right to review approval.

Approval 240455026 is valid between April 2024 and April 2029

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', is written over a horizontal line.

Ian Hughes
WRAS Approvals Manager

Approval Number 240455025
Test Report: J-00471743



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

22nd April 2024

Eurotech International LLC (Eurotherm PPR)
PO Box 1401, PC:211,
Raysut Industrial Estate,
Salalah,
Oman

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE- COMPONENTS.

5260

'Eurotherm PPR Fitting'. Green coloured, injection moulded PPR fitting. For use with water up to 85°C.

APPROVAL NUMBER: 240455025

APPROVAL HOLDER: EUROTECH INTERNATIONAL LLC (EUROTHERM PPR)

The Scheme reserves the right to review approval.

Approval 240455025 is valid between April 2024 and April 2029

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', is written over a horizontal line.

Ian Hughes
WRAS Approvals Manager